

LDWSP
12.3.412.1
7-15-02

Washington Oregon Gasoline Vapor Control Committee

This form will be accepted by any State
or Local Air Pollution Agency Requiring
compliance testing on gas station vapor
recovery equipment within the states of
Washington or Oregon

For Agency Use Only

Reviewed by: _____
Date: _____
☐ Passed ☐ Failed
(Attached reasons for test failure to this form)

Pressure Decay Test CARB Test Procedure TP-201.3 or Procedure in CARB Executive Order for Stage 2 Equipment

Station Name: Long Painting CO	Air Agency Registration No.:
Address: 1037 S Elm Grove	
City, State, Zip: Seattle WA	
Testing Company Name: Northwest Tank & Environmental Services, Inc.	Date/Time of Test: 8:00am Thursday, May 31, 2002
Address: 1720 100th Pl SE, Suite 101	Phone No.: 425-742-9622
City, State, Zip: Everett WA 98208-3826	

Type of Stage 1: ☐ Coaxial ☒ Dual Point ☐ Healy ☐ Other: _____
Type of Stage 2 system: ☐ Balance ☐ Tokheim ☐ Wayne ☒ OPW ☐ Gilbarco
Tanks Manifolder? Yes ☐ No ☒ Total Nozzles: 2 Tested with vapor cap: ON ☐ or OFF ☒

	Tank # 1	Tank # 2	Tank # 3	Tank # 4	
Number of Nozzles:	2				Total if Manifolder
Capacity:	10,000				
Product	3704				
Ullage:	6296				
Percent Ullage:	% 123	%	%	%	%

Percent Ullage = ullage (l) tank capacity x 100 (each tank ullage shall be greater than 500 but less than 25,000 gallons)

Test Results

	If Manifolder	Non-Manifolder			
		Tank # 1	Tank # 2	Tank # 3	Tank # 4
Initial Pressure	2.0" H2O	2.0" H2O	2.0" H2O	2.0" H2O	2.0" H2O
Pressure after 1 minute	" H2O 2.0	" H2O	" H2O	" H2O	" H2O
Pressure after 2 minutes	" H2O 2.0	" H2O	" H2O	" H2O	" H2O
Pressure after 3 minutes	" H2O 2.0	" H2O	" H2O	" H2O	" H2O
Pressure after 4 minutes	" H2O 1.99	" H2O	" H2O	" H2O	" H2O
Pressure after 5 minutes	" H2O 1.99	" H2O	" H2O	" H2O	" H2O

Allowable pressure from table (TP-201.3 or Applicable CARB Exec Exhibit #): 1.84

Allowable Pressure calculated (Formulas on back): _____

Person conducting the test:

Kris L. SNYDER
Print Name

Signature

5/31/2002
Date

Tank owner or authorized representative:

Brian Vance (Facilities Mgr)
Print Name

Signature

7/15/02
Date

WOGVACC Air To Liquid Ratio Test LCV:PSAPCA Updated 7/9/97

original mailed
to PSCA 7/16/02

Formulas →

USEPA SF



1410125

LP_00852